

TABLE 1

**Drinking Water Sampling for Lead Content  
 Steelville Community Unit School District #138  
 Steelville Elementary School  
 Sampled: November 29, 2017**

Sample ID	Location	Water Source	Results (ppb)
01	Kitchen 3-Bay (left)	Sink	12.6
01A	Kitchen 3-Bay (left)	Sink	<1.0
01B	Kitchen 3-Bay (left)	Sink	<1.0
02	Kitchen 3-Bay (right)	Sink	14.5
02A	Kitchen 3-Bay (right)	Sink	<1.0
03	Kitchen – Hand Wash	Sink	2.0
03A	Kitchen – Hand Wash	Sink	<1.0
04	Cafeteria	Fountain	4.0
04A	Cafeteria	Fountain	3.4
05	Hallway by Room 101 (left)	Fountain	<1.0
05A	Hallway by Room 101 (left)	Fountain	1.0
06	Hallway by Room 101 (right)	Fountain	<1.0
06A	Hallway by Room 101 (right)	Fountain	<1.0
07	Gymnasium	Fountain	77.1
07A	Gymnasium	Fountain	3.6
08	Hallway by Room 111 (left)	Fountain	<1.0
08A	Hallway by Room 111 (left)	Fountain	1.9
09	Hallway by Room 111 (right)	Fountain	<1.0
09A	Hallway by Room 111 (right)	Fountain	<1.0
10	South Hallway (left)	Fountain	<1.0
10A	South Hallway (left)	Fountain	1.3
11	South Hallway (right)	Fountain	1.3
11A	South Hallway (right)	Fountain	1.6
12	Ice Machine	Ice Machine	<1.0

A/B Samples were precautionary samples collected at 30 seconds following the “first draw” samples (A) and 3 minutes following the A sample (B).

#####

Water sources in excess of 20 ppb. Recommendation is to remove from service immediately. Do not return to service until re-testing confirms mitigation was effective.

#####

Water source is < 20 ppb, but still displays evidence of lead. Recommendation is to re-test source on an annual basis at a minimum